

AENOR

AENOR Product Certificate Clay products for construction



034/000994

AENOR certifies that the organization

PROCERAN, S.A.

registered office CR MONTORO-PUENTEGENIL, Km. 85 14920 AGUILAR DE LA FRONTERA
(Cordoba - España)

supplies P Units for protected masonry

in compliance with UNE-EN 771-1:2011+A1:2016 (EN 771-1:2011+A1:2015)

Nº Technical Form 0461404 (see annex)

Production site CR MONTORO-PUENTEGENIL, Km. 85 14920 AGUILAR DE LA FRONTERA
(Cordoba - España)

Certification scheme This Certificate has been granted in accordance with the stipulations of the
Specific Rules RP 034.14

This certificate supersedes 034/000994, dated 2017-11-03

First issued on 2009-06-01
Modified on 2020-02-04
Validity date 2025-02-04

Rafael GARCÍA MEIRO
Chief Executive Officer

Original Electronic Certificate

P UNITS FOR PROTECTED MASONRY
TECHNICAL FORM: 0461404



AENOR



Certified Product

MANUFACTURER - MADE IN PROCERAN, S.A. - AGUILAR DE LA FRONTERA (CÓRDOBA)
 PRODUCT DESCRIPTION: LIGHTENED (G3) P UNIT CAT I R-10,0 of 300 x 288 x 190
 DESIGNATION CODE: CL - P - I - 10 - 700(D1) - 300x288x190 - A - L0,550 - E(4,4,4) - N1630(D1) - G3 - FR53 - B0,15 - I≤4,5 - M≤0,2
 BRAND NAME: TERMOARCILLA DE 29
 INTENDED USES: EXTERNAL/INTERNAL ELEMENTS WITH ACOUSTIC, THERMAL INSULATION AND FIRE REQUIREMENTS; STRUCTURAL MASONRY SUSTAINING; COMMON LAYER MORTAR

PIECE SKETCH



TECHNICAL CHARACTERISTICS

Characteristic		Test method	Manufacturer ensured values	AENOR required values	
Appearance and structure	exfoliations and stratifications	Visual over 6 pieces	None		
	cracked units		≤ 2 unit of 6	≤ 2 unit of 6	
	chip units		≤ 1 unit of 6	≤ 1 unit of 6	
Dimensional tolerances (mm)	Mean value	UNE 67039 EX	Chips in perforated faces with mean dimension < 15 mm		
			length (l)	± 7	± 7
			width (w)	± 7	± 7
	height (h)		± 6	± 6	
	Range		length (l)	± 10	± 10
			width (w)	± 10	± 10
height (h)		± 8	± 8		
Wall thickness (mm)	protected face shells	EN 772-16	≥ 6,0	≥ 6,0	
	webs		≥ 3,0	≥ 3,0	
Plane parallelism of bed faces (mm)			N/A		
Flatness of bed faces (mm)	Diagonals	EN 772-20	l > 300 mm	≤ 4,0	
			300 ≥ l ≥ 250 mm	≤ 4,0	
			l ≤ 250 mm	≤ 4,0	
Percentage of voids (%)		EN 772-5	53	> 25; ≤ 60	
Tolerance (%)			Min: 48 - Máx: 58		
Volume of the largest void (% of (l x w x h))		EN 772-3/9/16	≤ 12,5	≤ 12,5	
Combined thickness of webs and shells (%)		EN 772-16	≥ 20	≥ 20	
Initial rate of water absorption (Kg/m ² x min)		EN 772-11	≤ 4,5	≤ 4,5	
Characteristic normalized compressive strength (N/mm ²)		EN 772-1	≥ 10,0	≥ 10,0	
Density	Gross dry (Kg/m ³)	EN 772-13	1.630		
	Net dry (Kg/m ³)		700		
	Tolerance (%)		D1	D1 (± 10%)	
Weight (g)		Annex D RP 34.14	Minimum value ensured: 11.200		
Durability (Freeze/thaw)		UNE 67028 EX	F0		
Thermal properties (Method)		Catalog CTE	Constructive Elements Catalog Value		
Apiece (W/m x k)			0,550		
Rwall (m ² x k/w)			0,680		
Water vapour permeability - μ		EN 1745	5/10		
Content of active soluble salts		EN 772-5	S0		
Moisture movement (mm/m)		UNE 67036	0,2		
Fire reaction		EN 13501-1	A1		
Bond strength (N/mm ²)		-----	0,15		
Accessory units			YES		
Remarks:					

Combined thickness declared corresponding at heat flow direction in the masonry

SPECIAL PARTS: SPRING OF 29, REMATE OF 29, MEDIUM TERMINATION OF 29, ENTIRE TERMINATION OF 29, CORNER OF 29, MODULATION OF 29, ZUNCHO 10, ZUNCHO 12, ZUNCHO 14, ZUNCHO 17, ZUNCHO 19, ZUNCHO 24, ZUNCHO 29, BLOCK 10, BLOCK BLOCK 4,5, CORNER 24 SMALL, CORNER CORNER 24.

AENOR